

APC by Schneider Electric - APC Back UPS Pro BX1350M Compact Tower 1350VA AVR LCD 120V : BX1350M

| Specifications | |
|--|--|
| ENERGY STAR Unique ID: | 2323358 |
| Brand Name: | APC by Schneider Electric |
| Model Name: | APC Back UPS Pro BX1350M Compact Tower 1350VA AVR LCD 120V |
| Model Number: | BX1350M |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | BX1350M |
| Active Output Power Rating Minimum Configuration (W): | 810 |
| Apparent Output Power Rating Minimum Configuration (VA): | 1350 |
| Topology (ac): | Line Interactive |
| Topology and Product Type Combined: | ac Line Interactive (VI) |
| Application: | Consumer |
| Rated Input Voltage (V rms): | 120-120 |
| Rated Input Frequency (Hz): | 60-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 60-60 |
| Rack Mountable: | No |
| Height (mm): | 250 |
| Width (mm): | 100 |
| Depth (mm): | 382 |
| Total Number of Outlets: | 10 |
| Number of Battery Backup and Surge Protected Outlets: | 5 |
| Number of Surge Protected Only Outlets: | 5 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Dependent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |

| Test Output Frequency (Hz): | 60 |
|--|--|
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 2.9 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 98.4 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.9 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 99.0 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.9 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.8 |
| Efficiency (%): | 98.8 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | N/A |
| Energy Storage System Runtime at 100% Load (min.): | 3 |
| Energy Storage System Runtime at 50% Load (min.): | 10 |
| Energy Storage System Warranty (yrs): | 2 |
| Energy Storage System Information URL: | http://www.apc.com/shop/us/en/products/P-APCRBC123 |
| Battery Recycling URL: | http://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp |
| Network Connections Available: | USB Port |
| Communication Protocols: | Other |
| Communication Protocol Other: | USB Power Summary |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | http://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp |
| Model Web Page URL: | http://www.apc.com/shop/us/en/products/P-BX1350M |
| Test Method Guidelines: | http://www.apc.com/us/en/who-we-are/sustainability/ |
| Date Available on Market: | 2019-01-01 |
| Date Certified: | 2018-07-16 |
| Markets: | United States |
| ENERGY STAR Certified: | Yes |
| | |

Additional Model Information

APC Back UPS Pro BX1350M Compact Tower 1350VA AVR LCD 120V Factory Serviced,BX1350MW,; Std Exch APC Back UPS Pro BX1350M Compact Tower 1350VA AVR LCD 120V,BX1350MQ,

UPC Codes 731304331773

Captured On: 06/17/2025