



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

CyberPower - OL3000RTXL2UHVTA : OL3000RTXL2UHVTA

Specifications

ENERGY STAR Unique ID:	2326401
Brand Name:	CyberPower
Model Name:	OL3000RTXL2UHVTA
Model Number:	OL3000RTXL2UHVTA
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	OL3000RTXL2UHV
Active Output Power Rating Minimum Configuration (W):	2700
Apparent Output Power Rating Minimum Configuration (VA):	3000
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Commercial,Consumer
Rated Input Voltage (V rms):	200-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	200-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	2
Height (mm):	88
Width (mm):	433
Depth (mm):	600
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent,Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	230
Test Input Frequency (Hz):	60
Test Output Voltage (V):	230
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	40.76

Efficiency at 25% Load Min Config Lowest Dependency (ac):	89.4
Efficiency at 50% Load Min Config Lowest Dependency (ac):	91.7
Efficiency at 75% Load Min Config Lowest Dependency (ac):	92.1
Efficiency at 100% Load Min Config Lowest Dependency (ac):	92.1
Weighted Efficiency Calc Min Config Lowest Dependency:	92.0
Efficiency (%):	92
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	No
Energy Storage System Runtime at 100% Load (min.):	4
Energy Storage System Runtime at 50% Load (min.):	11
Energy Storage System Warranty (yrs):	3
Energy Storage System Information URL:	http://www.cyberpowersystems.com/
Network Connections Available:	Serial Port,USB Port,Ethernet
Communication Protocols:	HTTPS,HTTP,SNMP (v1, 2 or 3)
Manufacturer Take Back Program:	Yes
Model Web Page URL:	http://www.cyberpowersystems.com
Test Method Guidelines:	http://www.cyberpowersystems.com/
Date Available on Market:	2016-06-10
Date Certified:	2018-09-19
Markets:	United States
ENERGY STAR Certified:	Yes

Captured On:
06/18/2025