



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

CyberPower - OL2200RTXL2UNTAA : OL2200RTXL2UNTAA

Specifications

ENERGY STAR Unique ID:	2326412
Brand Name:	CyberPower
Model Name:	OL2200RTXL2UNTAA
Model Number:	OL2200RTXL2UNTAA
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	OL2200RTXL2U
Active Output Power Rating Minimum Configuration (W):	1800
Apparent Output Power Rating Minimum Configuration (VA):	2200
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Commercial,Consumer
Rated Input Voltage (V rms):	100-125
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	100-125
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	2
Height (mm):	88
Width (mm):	433
Depth (mm):	600
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent,Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	120
Test Input Frequency (Hz):	60
Test Output Voltage (V):	120
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	35.86

Efficiency at 25% Load Min Config Lowest Dependency (ac):	89.6
Efficiency at 50% Load Min Config Lowest Dependency (ac):	91.9
Efficiency at 75% Load Min Config Lowest Dependency (ac):	92.0
Efficiency at 100% Load Min Config Lowest Dependency (ac):	91.9
Weighted Efficiency Calc Min Config Lowest Dependency:	91.9
Efficiency (%):	91.9
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	No
Energy Storage System Runtime at 100% Load (min.):	7
Energy Storage System Runtime at 50% Load (min.):	20
Energy Storage System Warranty (yrs):	3
Energy Storage System Information URL:	http://www.cyberpowersystems.com/
Network Connections Available:	Serial Port,USB Port,Ethernet
Communication Protocols:	HTTPS,HTTP,SNMP (v1, 2 or 3)
Manufacturer Take Back Program:	Yes
Model Web Page URL:	http://www.cyberpowersystems.com
Test Method Guidelines:	http://www.cyberpowersystems.com/
Date Available on Market:	2013-07-01
Date Certified:	2018-09-19
Markets:	United States
ENERGY STAR Certified:	Yes

Captured On:
06/18/2025