

EATON - 9PX8KPM: 9PX8KPM

Specifications	
ENERGY STAR Unique ID:	2331045
Brand Name:	EATON
Model Name:	9PX8KPM
Model Number:	9PX8KPM
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	9PX8KiPM
Active Output Power Rating Minimum Configuration (W):	7200
Apparent Output Power Rating Minimum Configuration (VA):	8000
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Data Center
Rated Input Voltage (V rms):	200-250
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	200-250
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	3
Height (mm):	130
Width (mm):	440
Depth (mm):	700
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	230
Test Input Frequency (Hz):	60
Test Output Voltage (V):	230
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	0.9984

Efficiency at 25% Load Min Config Lowest Dependency (ac): 94.4 Efficiency at 75% Load Min Config Lowest Dependency (ac): 94.7 Efficiency at 170% Load Min Config Lowest Dependency (ac): 94.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 94.6 Weighted Efficiency Calc Min Config Lowest Dependency: 94.6 Efficiency (%): 94.6 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: Property Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): 16 Energy Storage System Runtime at 50% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Marrantion URL: N/A Nework Connections Available: Serial Port,USB Port,Ethernet Communication Protocols: HTTPHITTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: O Date Available on		
Dependency (ac): 94.7 Efficiency at 75% Load Min Config Lowest Dependency (ac): 94.6 Weighted Efficiency Calc Min Config Lowest Dependency: 94.6 Weighted Efficiency Calc Min Config Lowest Dependency: 94.6 Efficiency (%): 94.6 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: 16 Energy Storage System Runtime at 100% Load (min.): 16 Energy Storage System Runtime at 50% Load (min.): 17 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Nework Connections Available: Serial Port,USB Port,Ethernet Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: <		92.4
Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Warranty (yrs): Energy Storage System Marranty (yrs): Energy Storage System Information URL: N/A Network Connections Available: Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: Denication Protocols Markets: United States, Switzerland, Taiwan, Japan, Canada		94.4
Dependency (ac): 94.6 Weighted Efficiency Calc Min Config Lowest Dependency: 94.6 Efficiency (%): 94.6 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Separate Enclosure Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Network Connections Available: Serial Port, USB Port, Ethernet Communication Protocols: HTTP, HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada		94.7
Dependency:Efficiency (%):94.6Modular UPS Module Tested Model Number:N/AEnergy Storage Mechanism:BatteryEnergy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:Separate EnclosureEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):5Energy Storage System Runtime at 50% Load (min.):16Energy Storage System Warranty (yrs):2Energy Storage System Information URL:N/ANetwork Connections Available:Serial Port,USB Port,EthernetCommunication Protocols:HTTP,HTTPSManufacturer Take Back Program:NoModel Web Page URL:http://www.eaton.com/us/en-us/skuPage.9PX8KPM.htmlTest Method Guidelines:N/ADate Available on Market:2018-12-06Date Certified:2018-12-06Markets:United States, Switzerland, Taiwan, Japan, Canada		94.6
Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Separate Enclosure Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Network Connections Available: Serial Port, USB Port, Ethernet Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada		94.6
Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Separate Enclosure Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 5 Energy Storage System Runtime at 50% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Network Connections Available: Serial Port, USB Port, Ethernet Communication Protocols: HTTP, HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada	Efficiency (%):	94.6
Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Separate Enclosure Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 5 Energy Storage System Runtime at 50% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Network Connections Available: Serial Port,USB Port,Ethernet Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Modular UPS Module Tested Model Number:	N/A
Energy Storage System Configuration: Separate Enclosure Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 5 Energy Storage System Runtime at 50% Load (min.): 16 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: N/A Network Connections Available: Serial Port, USB Port, Ethernet Communication Protocols: HTTP, HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Energy Storage Mechanism:	Battery
Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Information URL: N/A Network Connections Available: Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://wwww.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Warranty (yrs): Energy Storage System Information URL: N/A Network Connections Available: Serial Port,USB Port,Ethernet Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada	Energy Storage System Configuration:	Separate Enclosure
(min.):Energy Storage System Runtime at 50% Load (min.):16Energy Storage System Warranty (yrs):2Energy Storage System Information URL:N/ANetwork Connections Available:Serial Port,USB Port,EthernetCommunication Protocols:HTTP,HTTPSManufacturer Take Back Program:NoModel Web Page URL:http://www.eaton.com/us/en-us/skuPage.9PX8KPM.htmlTest Method Guidelines:N/ADate Available on Market:2018-12-06Date Certified:2018-12-06Markets:United States, Switzerland, Taiwan, Japan, Canada		No
(min.): Energy Storage System Warranty (yrs): Energy Storage System Information URL: N/A Network Connections Available: Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada		5
Energy Storage System Information URL: N/A Network Connections Available: Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada		16
Network Connections Available: Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: United States, Switzerland, Taiwan, Japan, Canada	Energy Storage System Warranty (yrs):	2
Communication Protocols: HTTP,HTTPS Manufacturer Take Back Program: No Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Energy Storage System Information URL:	N/A
Manufacturer Take Back Program: Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Network Connections Available:	Serial Port,USB Port,Ethernet
Model Web Page URL: http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 Markets: United States, Switzerland, Taiwan, Japan, Canada	Communication Protocols:	HTTP,HTTPS
Test Method Guidelines: N/A Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 United States, Switzerland, Taiwan, Japan, Canada	Manufacturer Take Back Program:	No
Date Available on Market: 2018-12-06 Date Certified: 2018-12-06 United States, Switzerland, Taiwan, Japan, Canada	Model Web Page URL:	http://www.eaton.com/us/en-us/skuPage.9PX8KPM.html
Date Certified:2018-12-06Markets:United States, Switzerland, Taiwan, Japan, Canada	Test Method Guidelines:	N/A
Markets: United States, Switzerland, Taiwan, Japan, Canada	Date Available on Market:	2018-12-06
	Date Certified:	2018-12-06
ENERGY STAR Certified: Yes	Markets:	United States, Switzerland, Taiwan, Japan, Canada
	ENERGY STAR Certified:	Yes

Captured On: 05/01/2025