

## Liebert - GXT4-5000RT208 : GXT4-5000RT208

Specifications	
ENERGY STAR Unique ID:	2332020
Brand Name:	Liebert
Model Name:	GXT4-5000RT208
Model Number:	GXT4-5000RT208
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	GXT4-5000RT208
Active Output Power Rating Minimum Configuration (W):	4000
Apparent Output Power Rating Minimum Configuration (VA):	5000
Topology (ac):	Multi-Mode Double Conversion
Topology and Product Type Combined:	ac - Other
Application:	Commercial,Consumer,Data Center
Rated Input Voltage (V rms):	200-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	200-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Height (mm):	173
Width (mm):	430
Depth (mm):	662
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent, Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	208
Test Input Frequency (Hz):	60
Test Output Voltage (V):	208
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	77.7
Efficiency at 25% Load Min Config Lowest Dependency (ac):	88.9

Efficiency at 50% Load Min Config Lowest Dependency (ac):91.9Efficiency at 75% Load Min Config Lowest Dependency (ac):92.0Strictency at 100% Load Min Config Lowest Dependency (ac):92.0Weighted Efficiency Calc Min Config Lowest Dependency:92.2Efficiency (%):92.2Modular UPS Module Tested Model Number:N/AEnergy Storage Mechanism:BatteryEnergy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:Separate EnclosureRoom:NoEnergy Storage System Runtime at 100% Load (min.):17Energy Storage System Nuntime at 50% Load (min.):17Energy Storage System Nuntime at 50% Load (min.):USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:Nips://www.vertivco.com/en-us/products-catalog/critical-power/ uninterruptible-power-supplies-ups/		
Dependency (ac):Image: Construct on the set of the s		91.9
Dependency (ac):Image: Constraint of the section of the		92.6
Dependency: 92.2   Fficiency (%): 92.2   Modular UPS Module Tested Model Number: N/A   Energy Storage Mechanism: Battery   Energy Storage System Technology: Valve Regulated Lead-acid Battery   Energy Storage System Configuration: Separate Enclosure   Energy Storage System Removable to Another Room: No   Energy Storage System Runtime at 100% Load (min.): 7   Energy Storage System Runtime at 50% Load (min.): 17   Energy Storage System Information URL: http://www.enersys.com/ http://www.eastpennunigy.com/   Network Connections Available: USB Port,Ethernet   Communication Protocols: Other   Manufacturer Take Back Program: No		92.0
Modular UPS Module Tested Model Number:N/AEnergy Storage Mechanism:BatteryEnergy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:Separate EnclosureEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):7Energy Storage System Runtime at 50% Load (min.):17Energy Storage System Narranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:http://www.vertivco.com/en-us/products-catalog/critical-power/		92.2
Energy Storage Mechanism:BatteryEnergy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:Separate EnclosureEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):7Energy Storage System Runtime at 50% Load (min.):17Energy Storage System Narranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/	Efficiency (%):	92.2
Energy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:Separate EnclosureEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):7Energy Storage System Runtime at 50% Load (min.):17Energy Storage System Warranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/	Modular UPS Module Tested Model Number:	N/A
Energy Storage System Configuration:Separate EnclosureEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):7Energy Storage System Runtime at 50% Load (min.):17Energy Storage System Warranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/	Energy Storage Mechanism:	Battery
Energy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):7Energy Storage System Runtime at 50% Load (min.):17Energy Storage System Warranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/	Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Room:Image: Constant of the section of th	Energy Storage System Configuration:	Separate Enclosure
(min.):Image: Constant of the section of		No
(min.):Image: Constraint of the system warranty (yrs):2Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/		7
Energy Storage System Information URL:http://www.enersys.com/ http://www.eastpennunigy.com/Network Connections Available:USB Port,EthernetCommunication Protocols:OtherManufacturer Take Back Program:NoModel Web Page URL:https://www.vertivco.com/en-us/products-catalog/critical-power/		17
Network Connections Available: USB Port,Ethernet   Communication Protocols: Other   Manufacturer Take Back Program: No   Model Web Page URL: https://www.vertivco.com/en-us/products-catalog/critical-power/	Energy Storage System Warranty (yrs):	2
Communication Protocols: Other   Manufacturer Take Back Program: No   Model Web Page URL: https://www.vertivco.com/en-us/products-catalog/critical-power/	Energy Storage System Information URL:	http://www.enersys.com/ http://www.eastpennunigy.com/
Manufacturer Take Back Program: No   Model Web Page URL: https://www.vertivco.com/en-us/products-catalog/critical-power/	Network Connections Available:	USB Port,Ethernet
Model Web Page URL:   https://www.vertivco.com/en-us/products-catalog/critical-power/	Communication Protocols:	Other
•	Manufacturer Take Back Program:	No
	Model Web Page URL:	
Test Method Guidelines: N/A	Test Method Guidelines:	N/A
Date Available on Market: 2014-03-31	Date Available on Market:	2014-03-31
<b>Date Certified:</b> 2018-12-24	Date Certified:	2018-12-24
Markets: United States, Taiwan, Japan, Canada	Markets:	United States, Taiwan, Japan, Canada
ENERGY STAR Certified: Yes	ENERGY STAR Certified:	Yes

Captured On: 06/18/2025