

APC by Schneider Electric - APC Smart-UPS SRT 3000VA 208V : SRT3000XLT

Specifications	
ENERGY STAR Unique ID:	2332847
Brand Name:	APC by Schneider Electric
Model Name:	APC Smart-UPS SRT 3000VA 208V
Model Number:	SRT3000XLT
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	SRT3000RMXLT
Active Output Power Rating Minimum Configuration (W):	2700
Apparent Output Power Rating Minimum Configuration (VA):	3000
Topology (ac):	Multi-Mode Double Conversion
Topology and Product Type Combined:	ac - Other
Application:	Commercial
Rated Input Voltage (V rms):	208-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	208-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	No
Height (mm):	432
Width (mm):	85
Depth (mm):	635
Total Number of Outlets:	3
Number of Battery Backup and Surge Protected Outlets:	3
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent, Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	240
Test Input Frequency (Hz):	60
Test Output Voltage (V):	240

Test Output Frequency (Hz): Total Input Power in W at 0% Load Min Config Chewest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 25% Load Min Config Highest Dependency (ac): Efficiency at 25% Load Min Config Highest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Highest Dependency (ac): Efficiency at 50% Load Min Config Highest Dependency (ac): Efficiency at 50% Load Min Config Highest Dependency (ac): Efficiency at 50% Load Min Config Highest Dependency (ac): Efficiency at 75% Load Min Config Highest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 10% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Highest Dependency (ac): Efficiency at 100% Load Min Config Highest Dependency (ac): Efficiency at 100% Load Min Config Highest Dependency: Weighted Efficiency Calc Min Config Highest Dependency: ### Weighted E		
Lowest Dependency (ac): 4.92 Total Input Power in W at 0% Load Min Config Hubest (Highest Dependency (ac): 89.9 Efficiency at 25% Load Min Config Lowest Dependency (ac): 96.3 Efficiency at 50% Load Min Config Lowest Dependency (ac): 93.0 Efficiency at 50% Load Min Config Lowest Dependency (ac): 95.5 Efficiency at 50% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 75% Load Min Config Highest Dependency (ac): 97.5 Efficiency at 100% Load Min Config Lowest Dependency (ac): 93.9 Efficiency at 100% Load Min Config Lowest Dependency (ac): 93.9 Efficiency at 100% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Lowest Dependency: 97.9 Weighted Efficiency Calc Min Config Lowest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Properties on Configuration Input Power Factor Dependency: 97.3 Minimum Configuration Input Power Factor Modular Tested Model Number: Na Efficiency (%): 93.5 Modular UPS Module Tested Model Number: Na Energy Storage System Technology: 40ke Regulated Lead-acid Battery Energy Storage System Removable to Another (min.): 10k	Test Output Frequency (Hz):	60
Highest Dependency (ac): 899 Efficiency at 25% Load Min Config Lowest Dependency (ac): 899 Efficiency at 25% Load Min Config Lowest Dependency (ac): 96.3 Efficiency at 50% Load Min Config Lowest Dependency (ac): 95.5 Efficiency at 50% Load Min Config Highest Dependency (ac): 96.5 Efficiency at 75% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 75% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Efficiency All Efficiency Calc Min Config Lowest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Papendency: 97.3 Minimum Configuration Input Power Factor Papendency: 97.4 Energy Storage System Technology: 98.5 Modular UPS Module Tested Model Number: N/A Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Romovable to Another Room: Nergy Storage System Romovable to Another Room:		55.84
Dependency (ac): Fifticiency at 25% Load Min Config Highest Dependency (ac): 96.3 Efficiency at 25% Load Min Config Lowest Dependency (ac): 33.0 Efficiency at 50% Load Min Config Lowest Dependency (ac): 96.5 Efficiency at 75% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 75% Load Min Config Highest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 10. Efficiency Storage Mechanism: N/A Energy Storage System Configuration: Integral Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: 1 Energy Storage System Runtime at 50% Load (min.): 1 1	•	44.92
Dependency (ac): 93.0 Efficiency at 50% Load Min Config Lowest Dependency (ac): 96.5 Efficiency at 50% Load Min Config Highest Dependency (ac): 93.6 Efficiency 37 5% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 75% Load Min Config Highest Dependency (ac): 93.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Weighted Efficiency Calc Min Config Highest Dependency (ac): 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 10. Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage System Echnology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 1 Energy Storage System Runtime at 50% Load (min.): 1 Energy Storage System Runtime at 50% Load (min.): <		89.9
Dependency (ac): 96.5 Efficiency at 75% Load Min Config Highest Dependency (ac): 95.6 Efficiency at 75% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 100% Load Min Config Highest Dependency (ac): 93.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 10.0 Minimum Configuration Input Power Factor Highest-Input Dependency: N/A Energy Storage Mechanism: Battery Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Anothe No. No. Energy Storage System Runtime at 100% Load (min.): 11 Energy Storage System Runtime at 100% Load (min.): 11 Energy Storage System Marranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL:		96.3
Dependency (ac): 93.6 Efficiency at 75% Load Min Config Lowest Dependency (ac): 97.5 Efficiency at 100% Load Min Config Lowest Dependency (ac): 93.9 Efficiency at 100% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 97.9 Weighted Efficiency Calc Min Config Lowest Dependency: 93.5 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Weighted Efficiency Calc Min Config Highest Dependency: 93.5 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: 1 Energy Storage System Warranty (yrs): 2 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 <th< th=""><th></th><th>93.0</th></th<>		93.0
Dependency (ac): 97.5 Efficiency at 10% Load Min Config Liwest Dependency (ac): 93.9 Efficiency at 10% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 10% Load Min Config Highest Dependency (ac): 97.9 Weighted Efficiency Calc Min Config Lowest Dependency: 93.5 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Wighted Efficiency Calc Min Config Highest Dependency: 93.5 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: 8attery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: 1.0 Energy Storage System Runtime at 100% Load (min.): 1.1 Energy Storage System Warranty (yrs): 2 Energy Storage System Marranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port,USB Port Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling <th></th> <th>96.5</th>		96.5
Dependency (ac): 93.9 Efficiency at 100% Load Min Config Lowest Dependency (ac): 97.9 Efficiency at 100% Load Min Config Highest Dependency (ac): 93.5 Weighted Efficiency Calc Min Config Lowest Dependency: 93.5 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Minimum Pombus Power Factor Highest-Input Dependency: N/A Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: 8attery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: Integral Energy Storage System Runtime at 100% Load (min.): 4 Energy Storage System Runtime at 100% Load (min.): 1 Energy Storage System Warranty (yrs): 2 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Energy Storage System Information URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Energy Storage System Marranty (yrs):	_	93.6
Dependency (ac): Efficiency at 100% Load Min Config Highest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Weighted Efficiency Calc Min Config Highest Dependency: Weighted Efficiency Calc Min Config Highest Dependency: Winimum Configuration Input Power Factor Highest-Input Dependency: Minimum Configuration Input Power Factor Highest-Input Dependency: ### Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Removable to Another Room: Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Marranty (yrs): Energy Storage System Marranty (yrs): Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Communication Protocol Other: Manufacturer Take Back Program: Weighted Efficiency Calc Min Config Lights Signaling (manufacturer Take Back Program URL: Nas Page Storage System Information URL: Province Storage System Information URL: District Storage System Signaling (Manufacturer Take Back Program URL: Manufacturer Take Back Program URL: Mitp://www.apc.com/company/us/en/sustainability/recycling-options/ Mitp://www.apc.com/company/us/en/sustainability/recycling-options/ Mitp://www.apc.com/company/us/en/sustainability/recycling-options/ Mitp://www.apc.com/company/us/en/sustainability/recycling-options/ Mitp://www.apc.com/company/us/en/sustainability/recycling-options/ Mitp://www.apc.com/company/		97.5
Dependency (ac): 93.5 Weighted Efficiency Calc Min Config Highest Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Removable to Another Room: No Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 1 Energy Storage System Runtime at 50% Load (min.): 11 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port, USB Port Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Http://www.apc.com/compa		93.9
Dependency: 97.3 Weighted Efficiency Calc Min Config Highests Dependency: 97.3 Minimum Configuration Input Power Factor Highest-Input Dependency: 1.0 Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Runtime at 100% Load (min.): 4 Energy Storage System Runtime at 100% Load (min.): 1 Energy Storage System Warranty (yrs): 2 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/s		97.9
Dependency: Interpretation Input Power Factor Highest-Input Dependency: 1.0 Efficiency (%): 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 4 Energy Storage System Runtime at 50% Load (min.): 1 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port, USB Port Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		93.5
Highest-Input Dependency: 93.5 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another (min.): No Energy Storage System Runtime at 100% Load (min.): 1 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port, USB Port Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		97.3
Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 4 Energy Storage System Runtime at 50% Load (min.): 11 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		1.0
Energy Storage Mechanism:BatteryEnergy Storage System Technology:Valve Regulated Lead-acid BatteryEnergy Storage System Configuration:IntegralEnergy Storage System Removable to Another Room:NoEnergy Storage System Runtime at 100% Load (min.):4Energy Storage System Runtime at 50% Load (min.):11Energy Storage System Warranty (yrs):2Energy Storage System Marranty (yrs):2Energy Storage System Information URL:http://www.apc.com/shop/us/en/products/P-APCRBC152Battery Recycling URL:http://www.apc.com/company/us/en/sustainability/recycling-options/Network Connections Available:Serial Port,USB PortCommunication Protocols:Other,Modbus RTUCommunication Protocol Other:USB Power Summary, Micro-Link, Simple SignalingManufacturer Take Back Program:YesManufacturer Take Back Program URL:http://www.apc.com/company/us/en/sustainability/recycling-options/	Efficiency (%):	93.5
Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load (min.): 4 Energy Storage System Runtime at 50% Load (min.): 11 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port, USB Port Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Modular UPS Module Tested Model Number:	N/A
Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Energy Storage Mechanism:	Battery
Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port, USB Port Communication Protocols: Other, Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Energy Storage System Configuration:	Integral
(min.): Energy Storage System Runtime at 50% Load (min.): 11 Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		No
(min.): Energy Storage System Warranty (yrs): 2 Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		4
Energy Storage System Information URL: http://www.apc.com/shop/us/en/products/P-APCRBC152 Battery Recycling URL: http://www.apc.com/company/us/en/sustainability/recycling-options/ Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/		11
Battery Recycling URL: Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Energy Storage System Warranty (yrs):	2
Network Connections Available: Serial Port,USB Port Communication Protocols: Other,Modbus RTU Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Energy Storage System Information URL:	http://www.apc.com/shop/us/en/products/P-APCRBC152
Communication Protocols: Other, Modbus RTU USB Power Summary, Micro-Link, Simple Signaling Manufacturer Take Back Program: Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Battery Recycling URL:	http://www.apc.com/company/us/en/sustainability/recycling-options/
Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling Yes Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Network Connections Available:	Serial Port,USB Port
Manufacturer Take Back Program: Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Communication Protocols:	Other, Modbus RTU
Manufacturer Take Back Program URL: http://www.apc.com/company/us/en/sustainability/recycling-options/	Communication Protocol Other:	USB Power Summary, Micro-Link, Simple Signaling
	Manufacturer Take Back Program:	Yes
Model Web Page URL: http://www.apc.com/shop/us/en/products/P-SRT3000XLT	Manufacturer Take Back Program URL:	http://www.apc.com/company/us/en/sustainability/recycling-options/
	Model Web Page URL:	http://www.apc.com/shop/us/en/products/P-SRT3000XLT

Test Method Guidelines:	http://www.apc.com/company/us/en/sustainability/energy-efficiency/
Date Available on Market:	2015-10-26
Date Certified:	2018-12-28
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

Additional Model Information

APC Smart-UPS SRT 3000VA 208V Factory Serviced, SRT3000XLT-W,; Std Exch APC Smart-UPS SRT 3000VA 208V, SRT30 00XLTQ,

UPC Codes 731304317685

Captured On: 06/19/2025