



ENERGY STAR CERTIFIED

# Uninterruptible Power Supplies

## APC by Schneider Electric - APC Smart-UPS SRT 10000VA RM 208V IEC : SRT10KRMXLT-IEC

### Specifications

ENERGY STAR Unique ID:	2333237
Brand Name:	APC by Schneider Electric
Model Name:	APC Smart-UPS SRT 10000VA RM 208V IEC
Model Number:	SRT10KRMXLT-IEC
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	SRT10KRMXLT
Active Output Power Rating Minimum Configuration (W):	10000
Apparent Output Power Rating Minimum Configuration (VA):	10000
Topology (ac):	Multi-Mode Double Conversion
Topology and Product Type Combined:	ac - Other
Application:	Commercial
Rated Input Voltage (V rms):	208-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	208-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	6
Height (mm):	263
Width (mm):	432
Depth (mm):	715
Total Number of Outlets:	7
Number of Battery Backup and Surge Protected Outlets:	7
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent,Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	240
Test Input Frequency (Hz):	60

<b>Test Output Voltage (V):</b>	240
<b>Test Output Frequency (Hz):</b>	60
<b>Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):</b>	94.12
<b>Total Input Power in W at 0% Load Min Config Highest Dependency (ac):</b>	73.2
<b>Efficiency at 25% Load Min Config Lowest Dependency (ac):</b>	94.0
<b>Efficiency at 25% Load Min Config Highest Dependency (ac):</b>	97.0
<b>Efficiency at 50% Load Min Config Lowest Dependency (ac):</b>	95.2
<b>Efficiency at 50% Load Min Config Highest Dependency (ac):</b>	98.4
<b>Efficiency at 75% Load Min Config Lowest Dependency (ac):</b>	95.2
<b>Efficiency at 75% Load Min Config Highest Dependency (ac):</b>	98.8
<b>Efficiency at 100% Load Min Config Lowest Dependency (ac):</b>	95.0
<b>Efficiency at 100% Load Min Config Highest Dependency (ac):</b>	99.0
<b>Weighted Efficiency Calc Min Config Lowest Dependency:</b>	95.1
<b>Weighted Efficiency Calc Min Config Highest Dependency:</b>	98.7
<b>Minimum Configuration Input Power Factor Highest-Input Dependency:</b>	0.98
<b>Efficiency (%):</b>	95.1
<b>Modular UPS Module Tested Model Number:</b>	N/A
<b>Energy Storage Mechanism:</b>	Battery
<b>Energy Storage System Technology:</b>	Valve Regulated Lead-acid Battery
<b>Energy Storage System Configuration:</b>	Integral
<b>Energy Storage System Removable to Another Room:</b>	No
<b>Energy Storage System Runtime at 100% Load (min.):</b>	4
<b>Energy Storage System Runtime at 50% Load (min.):</b>	11
<b>Energy Storage System Warranty (yrs):</b>	2
<b>Energy Storage System Information URL:</b>	<a href="http://www.apc.com/shop/us/en/products/P-APCRBC140">http://www.apc.com/shop/us/en/products/P-APCRBC140</a>
<b>Battery Recycling URL:</b>	<a href="http://www.apc.com/company/us/en/sustainability/recycling-options/">http://www.apc.com/company/us/en/sustainability/recycling-options/</a>
<b>Network Connections Available:</b>	Serial Port,USB Port,Ethernet
<b>Communication Protocols:</b>	Modbus TCP,HTTPS,Other,HTTP,Modbus RTU
<b>Communication Protocol Other:</b>	USB Power Summary, Micro-Link, Simple Signaling
<b>Manufacturer Take Back Program:</b>	Yes
<b>Manufacturer Take Back Program URL:</b>	<a href="http://www.apc.com/company/us/en/sustainability/recycling-options/">http://www.apc.com/company/us/en/sustainability/recycling-options/</a>

Model Web Page URL:	http://www.apc.com/shop/us/en/products/P-SRT10KXLT
Test Method Guidelines:	http://www.apc.com/company/us/en/sustainability/energy-efficiency/
Date Available on Market:	2015-01-29
Date Certified:	2018-12-28
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

Additional Model Information

APC Smart-UPS SRT 10000VA 208V IEC Factory Serviced,SRT10KRXLTIECW,, Std Exch APC Smart-UPS SRT 10000VA R M 208V IEC,SRT10KRXLTIECQ,

UPC Codes	731304304845
-----------	--------------

Captured On:  
06/13/2025