



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

APC by Schneider Electric - APC Back-UPS 350VA X545 120V : BK350X545

Specifications

| | |
|--|--|
| ENERGY STAR Unique ID: | 2333439 |
| Brand Name: | APC by Schneider Electric |
| Model Name: | APC Back-UPS 350VA X545 120V |
| Model Number: | BK350X545 |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | BK350 |
| Active Output Power Rating Minimum Configuration (W): | 210 |
| Apparent Output Power Rating Minimum Configuration (VA): | 350 |
| Topology (ac): | Passive Standby |
| Topology and Product Type Combined: | Alternating Current (ac) - Offline (VFD) |
| Application: | Consumer |
| Rated Input Voltage (V rms): | 120-120 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | No |
| Height (mm): | 165 |
| Width (mm): | 91 |
| Depth (mm): | 284 |
| Total Number of Outlets: | 6 |
| Number of Battery Backup and Surge Protected Outlets: | 3 |
| Number of Surge Protected Only Outlets: | 3 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Dependent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |

| | |
|---|---|
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 2.228 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 96.1 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.0 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 98.6 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.8 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.0 |
| Efficiency (%): | 98 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 5 |
| Energy Storage System Runtime at 50% Load (min.): | 20 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | http://www.apc.com/shop/us/en/products/P-RBC2 |
| Battery Recycling URL: | http://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp |
| Network Connections Available: | USB Port |
| Communication Protocols: | Other |
| Communication Protocol Other: | USB Power Summary |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | http://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp |
| Model Web Page URL: | http://www.apc.com/shop/us/en/products/P-BK350X545 |
| Test Method Guidelines: | http://www.apc.com/us/en/who-we-are/sustainability/ |
| Date Available on Market: | 2008-04-03 |
| Date Certified: | 2019-02-12 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Additional Model Information

APC Back-UPS 350VA X545 120V Factory Serviced,BK350X545W,, Std Exch APC Back-UPS 350VA X545 120V,BK350X545Q,

| | |
|------------------|--------------|
| UPC Codes | 731304260271 |
|------------------|--------------|

Captured On:
05/01/2025