

## APC by Schneider Electric - Back UPS PRO BR 1000VA SineWave 10 Outlets 2 USB Charging Ports AVR LCD interface : BR1000MS

## Specifications

| ENERGY STAR Unique ID:                                      | 2333484   |
|---|---|
| Brand Name:   | APC by Schneider Electric   |
| Model Name:   | Back UPS PRO BR 1000VA SineWave 10 Outlets 2 USB Charging Ports AVR LCD interface |
| Model Number:   | BR1000MS  |
| Power Conversion Mechanism:                                 | Static  |
| Minimum Configuration Tested Model<br>Number:               | BR1000MS  |
| Active Output Power Rating Minimum<br>Configuration (W):    | 600   |
| Apparent Output Power Rating Minimum<br>Configuration (VA): | 1000  |
| Topology (ac):  | Line Interactive  |
| Topology and Product Type Combined:                         | ac Line Interactive (VI)  |
| Application:  | Consumer  |
| Rated Input Voltage (V rms):                                | 120-120   |
| Rated Input Frequency (Hz):                                 | 60-60   |
| Rated Output Voltage (V):                                   | 120-120   |
| Rated Output Frequency (Hz):                                | 60-60   |
| Rack Mountable:   | No  |
| Height (mm):  | 260   |
| Width (mm):   | 100   |
| Depth (mm):   | 368   |
| Total Number of Outlets:                                    | 10  |
| Number of Battery Backup and Surge<br>Protected Outlets:    | 6   |
| Number of Surge Protected Only Outlets:                     | 4   |
| Normal Mode(s) Input Dependency<br>Characteristic (ac):     | Voltage Independent   |
| Modular UPS:  | No  |
| Number of Normal Modes:                                     | Single-normal-mode  |
| Default Normal Mode (ac):                                   | Voltage Independent   |
| Test Input Voltage (V rms):                                 | 120   |

| Test Input Frequency (Hz):  | 60   |
|---|--|
| Test Output Voltage (V):  | 120  |
| Test Output Frequency (Hz):   | 60   |
| Total Input Power in W at 0% Load Min Config<br>Lowest Dependency (ac): | 2.968  |
| Efficiency at 25% Load Min Config Lowest<br>Dependency (ac):            | 97.9   |
| Efficiency at 50% Load Min Config Lowest<br>Dependency (ac):            | 98.8   |
| Efficiency at 75% Load Min Config Lowest<br>Dependency (ac):            | 99.0   |
| Efficiency at 100% Load Min Config Lowest<br>Dependency (ac):           | 99.1   |
| Weighted Efficiency Calc Min Config Lowest<br>Dependency:               | 99.0   |
| Efficiency (%):   | 99   |
| Modular UPS Module Tested Model Number:                                 | N/A  |
| Energy Storage Mechanism:   | Battery  |
| Energy Storage System Technology:                                       | Valve Regulated Lead-acid Battery  |
| Energy Storage System Configuration:                                    | Integral   |
| Energy Storage System Removable to Another Room:                        | No   |
| Energy Storage System Runtime at 100% Load (min.):                      | 4  |
| Energy Storage System Runtime at 50% Load (min.):                       | 12   |
| Energy Storage System Warranty (yrs):                                   | 3  |
| Energy Storage System Information URL:                                  | http://www.apc.com/shop/us/en/products/P-APCRBC160                           |
| Battery Recycling URL:  | http://www.apc.com/us/en/who-we-are/sustainability/recycling-<br>options.jsp |
| Network Connections Available:  | USB Port   |
| Communication Protocols:  | Other  |
| Communication Protocol Other:   | USB Power Summary  |
| Manufacturer Take Back Program:   | Yes  |
| Manufacturer Take Back Program URL:                                     | http://www.apc.com/us/en/who-we-are/sustainability/recycling-<br>options.jsp |
| Model Web Page URL:   | http://www.apc.com/shop/us/en/products/P-BR1000MS                            |
| Test Method Guidelines:   | http://www.apc.com/us/en/who-we-are/sustainability/                          |
| Date Available on Market:   | 2017-12-03   |
| Date Certified:   | 2019-02-12   |
| Markets:  | United States, Canada  |
| ENERGY STAR Certified:  | Yes  |
|   |  |

## Additional Model Information

Back UPS PRO BR 1000VA SineWave 10 Outlets 2 USB Charging Ports AVR LCD interface Factory Serviced,BR1000MSW,; Std Exch Back UPS PRO BR 1000VA SineWave 10 Outlets 2 USB Charging Ports AVR LCD interface,BR1000MSQ,

**UPC Codes** 731304335382

**Captured On:** 04/30/2025