



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

APC by Schneider Electric - APC Smart-UPS SRT 3000VA 120V TAA : SRT3000XLAUS

Specifications

| | |
|--|---|
| ENERGY STAR Unique ID: | 2333701 |
| Brand Name: | APC by Schneider Electric |
| Model Name: | APC Smart-UPS SRT 3000VA 120V TAA |
| Model Number: | SRT3000XLAUS |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | SRT3000RMXLA |
| Active Output Power Rating Minimum Configuration (W): | 2700 |
| Apparent Output Power Rating Minimum Configuration (VA): | 3000 |
| Topology (ac): | Multi-Mode Double Conversion |
| Topology and Product Type Combined: | ac - Other |
| Application: | Commercial |
| Rated Input Voltage (V rms): | 120-120 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | No |
| Height (mm): | 432 |
| Width (mm): | 85 |
| Depth (mm): | 635 |
| Total Number of Outlets: | 9 |
| Number of Battery Backup and Surge Protected Outlets: | 9 |
| Number of Surge Protected Only Outlets: | 0 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Independent,Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Multiple-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Independent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |

| | |
|--|---|
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 44.16 |
| Total Input Power in W at 0% Load Min Config Highest Dependency (ac): | 34.48 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 91.2 |
| Efficiency at 25% Load Min Config Highest Dependency (ac): | 94.9 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 93.2 |
| Efficiency at 50% Load Min Config Highest Dependency (ac): | 97.0 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 93.3 |
| Efficiency at 75% Load Min Config Highest Dependency (ac): | 97.5 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 92.5 |
| Efficiency at 100% Load Min Config Highest Dependency (ac): | 97.6 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 93.0 |
| Weighted Efficiency Calc Min Config Highest Dependency: | 97.4 |
| Minimum Configuration Input Power Factor Highest-Input Dependency: | 1.0 |
| Efficiency (%): | 93 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 3 |
| Energy Storage System Runtime at 50% Load (min.): | 10 |
| Energy Storage System Warranty (yrs): | 2 |
| Energy Storage System Information URL: | http://www.apc.com/shop/us/en/products/P-APCRBC152 |
| Battery Recycling URL: | http://www.apc.com/company/us/en/sustainability/recycling-options/ |
| Network Connections Available: | Serial Port,USB Port |
| Communication Protocols: | Other,Modbus RTU |
| Communication Protocol Other: | USB Power Summary, Micro-Link, Simple Signaling |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | http://www.apc.com/company/us/en/sustainability/recycling-options/ |
| Model Web Page URL: | http://www.apc.com/shop/us/en/products/P-SRT3000XLA |

| | |
|----------------------------------|---|
| Test Method Guidelines: | http://www.apc.com/company/us/en/sustainability/energy-efficiency/ |
| Date Available on Market: | 2020-02-11 |
| Date Certified: | 2019-02-14 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Additional Model Information

APC Smart-UPS SRT 3000VA 120V TAA Factory Service,SRT3000XLAUSW,; Std Exch APC Smart-UPS SRT 3000VA 120V TAA,SRT3000XLAUSQ,

| | |
|------------------|--------------|
| UPC Codes | 731304340478 |
|------------------|--------------|

Captured On:
06/19/2025