

Delta - RT-6K : RT-6K (UPS602R2RT2N0B8)

Specifications	
ENERGY STAR Unique ID:	2336735
Brand Name:	Delta
Model Name:	RT-6K
Model Number:	RT-6K (UPS602R2RT2N0B8)
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	RT-6K (UPS602R2RT2N035)
Active Output Power Rating Minimum Configuration (W):	6000
Apparent Output Power Rating Minimum Configuration (VA):	6000
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Commercial
Rated Input Voltage (V rms):	200-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	200-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Height (mm):	88
Width (mm):	440
Depth (mm):	430
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	240
Test Input Frequency (Hz):	60
Test Output Voltage (V):	240
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	53.0
Efficiency at 25% Load Min Config Lowest Dependency (ac):	92.0

Efficiency at 50% Load Min Config Lowest Dependency (ac):	94.2
Efficiency at 75% Load Min Config Lowest Dependency (ac):	94.5
Efficiency at 100% Load Min Config Lowest Dependency (ac):	94.0
Weighted Efficiency Calc Min Config Lowest Dependency:	94.3
Efficiency (%):	94.3
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Separate Enclosure
Energy Storage System Removable to Another Room:	Yes
Energy Storage System Runtime at 100% Load (min.):	3
Energy Storage System Runtime at 50% Load (min.):	9
Energy Storage System Warranty (yrs):	3
Energy Storage System Information URL:	N/A
Network Connections Available:	Serial Port,Ethernet,USB Port
Communication Protocols:	Other
Communication Protocol Other:	USB HID Power Devices
Manufacturer Take Back Program:	No
Model Web Page URL:	N/A
Test Method Guidelines:	N/A
Date Available on Market:	2019-04-15
Date Certified:	2019-03-21
Markets:	United States, Taiwan, Canada
ENERGY STAR Certified:	Yes

Additional Model Information

RT-5K,RT-5K (UPS502R2RT2N035),; RT-5K,RT-5K (UPS502R2RT2N0B8),; RT-6K,RT-6K (UPS602R2RT2N035),

Captured On: 06/18/2025