



ENERGY STAR CERTIFIED

# Uninterruptible Power Supplies

## Fuji Electric - UPS7400WX-T3U : UPS7400WX-T3U/1000

### Specifications

ENERGY STAR Unique ID:	2339232
Brand Name:	Fuji Electric
Model Name:	UPS7400WX-T3U
Model Number:	UPS7400WX-T3U/1000
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	UPS7400WX-T3U
Active Output Power Rating Minimum Configuration (W):	1000000
Apparent Output Power Rating Minimum Configuration (VA):	1000000
Active Output Power Rating Maximum Configuration (W):	1000000
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Data Center,Commercial
Rated Input Voltage (V rms):	336-528
Rated Input Frequency (Hz):	57-63
Rated Output Voltage (V):	480-480
Rated Output Frequency (Hz):	60-60
Rack Mountable:	No
Height (mm):	2020
Width (mm):	3350
Depth (mm):	830
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent
Modular UPS:	Yes
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	480
Test Input Frequency (Hz):	60
Test Output Voltage (V):	480
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	7200.0

<b>Total Input Power in W at 0% Load Min Config Highest Dependency (ac):</b>	8600.0
<b>Efficiency at 25% Load Min Config Lowest Dependency (ac):</b>	96.3
<b>Efficiency at 25% Load Min Config Highest Dependency (ac):</b>	96.3
<b>Efficiency at 50% Load Min Config Lowest Dependency (ac):</b>	97.2
<b>Efficiency at 50% Load Min Config Highest Dependency (ac):</b>	98.4
<b>Efficiency at 75% Load Min Config Lowest Dependency (ac):</b>	97.2
<b>Efficiency at 75% Load Min Config Highest Dependency (ac):</b>	98.7
<b>Efficiency at 100% Load Min Config Lowest Dependency (ac):</b>	97.0
<b>Efficiency at 100% Load Min Config Highest Dependency (ac):</b>	98.7
<b>Weighted Efficiency Calc Min Config Lowest Dependency:</b>	97.0
<b>Weighted Efficiency Calc Min Config Highest Dependency:</b>	98.0
<b>Minimum Configuration Input Power Factor Highest-Input Dependency:</b>	1.0
<b>Efficiency (%):</b>	97
<b>Modular UPS Module Tested Model Number:</b>	N/A
<b>Energy Storage Mechanism:</b>	Battery
<b>Energy Storage System Technology:</b>	Valve Regulated Lead-acid Battery
<b>Energy Storage System Configuration:</b>	Separate Enclosure
<b>Energy Storage System Removable to Another Room:</b>	N/A
<b>Energy Storage System Runtime at 100% Load (min.):</b>	N/A
<b>Energy Storage System Runtime at 50% Load (min.):</b>	N/A
<b>Energy Storage System Warranty (yrs):</b>	3
<b>Energy Storage System Information URL:</b>	N/A
<b>Network Connections Available:</b>	Serial Port
<b>Communication Protocols:</b>	SNMP (v1, 2 or 3),Modbus RTU
<b>Manufacturer Take Back Program:</b>	No
<b>Model Web Page URL:</b>	in preparation
<b>Test Method Guidelines:</b>	N/A
<b>Date Available on Market:</b>	2019-04-01
<b>Date Certified:</b>	2019-05-23
<b>Markets:</b>	United States
<b>ENERGY STAR Certified:</b>	Yes

**Captured On:**

06/19/2025