

## APC by Schneider Electric - APC Smart-UPS 1000VA LCD RM 2U 120V with SmartConnect : SMT1000RM2UC

Specifications	
ENERGY STAR Unique ID:	2340241
Brand Name:	APC by Schneider Electric
Model Name:	APC Smart-UPS 1000VA LCD RM 2U 120V with SmartConnect
Model Number:	SMT1000RM2UC
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	SMT1000RM2UC
Active Output Power Rating Minimum Configuration (W):	700
Apparent Output Power Rating Minimum Configuration (VA):	1000
Topology (ac):	Line Interactive
Topology and Product Type Combined:	ac Line Interactive (VI)
Application:	Commercial
Rated Input Voltage (V rms):	110-125
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	110-125
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	2
Height (mm):	86
Width (mm):	432
Depth (mm):	477
Total Number of Outlets:	6
Number of Battery Backup and Surge Protected Outlets:	6
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage Independent
Test Input Voltage (V rms):	125
Test Input Frequency (Hz):	60

Test Output Frequency (Hz):6Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):3Efficiency at 25% Load Min Config Lowest Dependency (ac):4Efficiency at 50% Load Min Config Lowest Dependency (ac):4Efficiency at 50% Load Min Config Lowest Dependency (ac):4Efficiency at 75% Load Min Config Lowest Dependency (ac):4	125   60   3.548   97.9   98.7   98.9   92.0
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):Second Min Config Lowest Dependency (ac):Efficiency at 25% Load Min Config Lowest Dependency (ac):Second Min Config Lowest Dependency (ac):Efficiency at 75% Load Min Config Lowest Dependency (ac):Second Min Config Lowest Dependency (ac):Efficiency at 100% Load Min Config LowestSecond Min Config Lowest	3.548 97.9   98.7 98.9
Lowest Dependency (ac):Efficiency at 25% Load Min Config Lowest Dependency (ac):9Efficiency at 50% Load Min Config Lowest Dependency (ac):9Efficiency at 75% Load Min Config Lowest Dependency (ac):9Efficiency at 75% Load Min Config Lowest Dependency (ac):9Efficiency at 100% Load Min Config Lowest9	97.9 98.7 98.9
Dependency (ac):Efficiency at 50% Load Min Config Lowest Dependency (ac):Efficiency at 75% Load Min Config Lowest Dependency (ac):Efficiency at 100% Load Min Config Lowest	98.7 98.9
Dependency (ac):Efficiency at 75% Load Min Config LowestDependency (ac):Efficiency at 100% Load Min Config Lowest	98.9
Dependency (ac): Efficiency at 100% Load Min Config Lowest	
Dependency (dc).	98.9
Weighted Efficiency Calc Min Config Lowest Dependency:	98.8
Efficiency (%):	98.8
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	Νο
Energy Storage System Runtime at 100% Load 8 (min.):	8
Energy Storage System Runtime at 50% Load (min.):	29
Energy Storage System Warranty (yrs):	2
Energy Storage System Information URL:	https://www.apc.com/shop/us/en/products/P-APCRBC132
	https://www.apc.com/us/en/who-we-are/sustainability/recycling- options.jsp
Network Connections Available:	Serial Port,USB Port,Ethernet
Communication Protocols:	Other,Modbus TCP,Modbus RTU
Communication Protocol Other:	USB Power Summary, Simple Signalling, SmartConnect
Manufacturer Take Back Program:	Yes
-	https://www.apc.com/us/en/who-we-are/sustainability/recycling- options.jsp
Model Web Page URL:	https://www.apc.com/shop/us/en/products/P-SMT1000RM2UC
Test Method Guidelines:	https://www.apc.com/us/en/who-we-are/sustainability/
Date Available on Market: 2	2020-06-01
Date Certified: 2	2019-06-24
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

## Additional Model Information

APC Smart-UPS 1000VA LCD RM 2U 120V with SmartConnect Factory Serviced,SMT1000RM2UCW,; Std Exch APC Smart -UPS 1000VA LCD RM 2U 120V with SmartConnect,SMT1000RM2UCQ,

Captured On: 04/30/2025