



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

CyberPower - CP1500PFCLCDa : CP1500PFCLCDa

Specifications

| | |
|--|--|
| ENERGY STAR Unique ID: | 2341720 |
| Brand Name: | CyberPower |
| Model Name: | CP1500PFCLCDa |
| Model Number: | CP1500PFCLCDa |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | CP1350PFCLCDa |
| Active Output Power Rating Minimum Configuration (W): | 880 |
| Apparent Output Power Rating Minimum Configuration (VA): | 1350 |
| Maximum Configuration Tested Model Number: | CP1500PFCLCDa |
| Active Output Power Rating Maximum Configuration (W): | 1000 |
| Topology (ac): | Passive Standby |
| Topology and Product Type Combined: | Alternating Current (ac) - Offline (VFD) |
| Application: | Consumer,Commercial |
| Rated Input Voltage (V rms): | 120-120 |
| Rated Input Frequency (Hz): | 60-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 60-60 |
| Rack Mountable: | No |
| Height (mm): | 280 |
| Width (mm): | 100 |
| Depth (mm): | 354 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage Independent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage Independent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |
| Test Output Frequency (Hz): | 60 |

| | |
|---|--------------------------------------|
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 3.56 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 98.2 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.8 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 98.9 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.8 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.8 |
| Total Input Power in W at 0% Load Max Config Lowest Dependency (ac): | 2.66 |
| Efficiency at 25% Load Max Config Lowest Dependency (ac): | 98.8 |
| Efficiency at 50% Load Max Config Lowest Dependency (ac): | 99.0 |
| Efficiency at 75% Load Max Config Lowest Dependency (ac): | 99.0 |
| Efficiency at 100% Load Max Config Lowest Dependency (ac): | 99.0 |
| Weighted Efficiency Calc Max Config Lowest Dependency: | 99.0 |
| Efficiency (%): | 98.8 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 2 |
| Energy Storage System Runtime at 50% Load (min.): | 9 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | N/A |
| Network Connections Available: | Serial Port,Ethernet,USB Port |
| Communication Protocols: | HTTP,HTTPS,Other,SNMP (v1, 2 or 3) |
| Communication Protocol Other: | HID, CyberPower serial Protocol (v2) |
| Manufacturer Take Back Program: | No |
| Model Web Page URL: | No (Not yet available) |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2019-07-31 |
| Date Certified: | 2019-07-28 |
| Markets: | United States, Taiwan, Japan, Canada |
| ENERGY STAR Certified: | Yes |

Additional Model Information

CP1350PFCLCDa,CP1350PFCLCDa,, CP1460PFCLCDa,CP1460PFCLCDa,, CST1350SUC,CST1350SUC,;
CST1460SUC,CST1460SUC,, CST1500SUC,CST1500SUC,, GX1500U,GX1500U,

Captured On:
04/30/2025