



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

Right Power - TITAN ONE + 10K : TITAN ONE + 10K

Specifications

ENERGY STAR Unique ID:	2347480
Brand Name:	Right Power
Model Name:	TITAN ONE + 10K
Model Number:	TITAN ONE + 10K
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	TITAN ONE + 10K
Active Output Power Rating Minimum Configuration (W):	10000
Apparent Output Power Rating Minimum Configuration (VA):	10000
Topology (ac):	Multi-Mode Double Conversion
Topology and Product Type Combined:	ac - Other
Application:	Data Center,Commercial
Rated Input Voltage (V rms):	220-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	208-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	No
Height (mm):	570
Width (mm):	250
Depth (mm):	560
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent,Voltage and Frequency Dependent
Modular UPS:	No
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	230
Test Input Frequency (Hz):	50
Test Output Voltage (V):	240
Test Output Frequency (Hz):	50
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	106.0
Efficiency at 25% Load Min Config Lowest Dependency (ac):	92.6

Efficiency at 50% Load Min Config Lowest Dependency (ac):	93.9
Efficiency at 75% Load Min Config Lowest Dependency (ac):	93.9
Efficiency at 100% Load Min Config Lowest Dependency (ac):	93.4
Weighted Efficiency Calc Min Config Lowest Dependency:	93.8
Efficiency (%):	93.8
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	No
Energy Storage System Runtime at 100% Load (min.):	2
Energy Storage System Runtime at 50% Load (min.):	9
Energy Storage System Warranty (yrs):	1
Energy Storage System Information URL:	N/A
Network Connections Available:	USB Port
Communication Protocols:	HTTP,HTTPS,SNMP (v1, 2 or 3),Modbus RTU
Manufacturer Take Back Program:	No
Model Web Page URL:	http://www.rightpowerups.com.my/
Test Method Guidelines:	N/A
Date Available on Market:	2017-02-01
Date Certified:	2019-09-25
Markets:	United States
ENERGY STAR Certified:	Yes

Captured On:
05/01/2025