

Schneider Electric - Galaxy VS UPS 80kW 480V for up to 5 internal 9Ah smart modular battery strings, Start-up 5x8 : GVSUPS80K0B5GS

Specifications

| • | |
|-------------------------------------------------------------|----------------------------------------------------------------------------------------------|
| ENERGY STAR Unique ID: | 2356236 |
| Brand Name: | Schneider Electric |
| Model Name: | Galaxy VS UPS 80kW 480V for up to 5 internal 9Ah smart modular battery strings, Start-up 5x8 |
| Model Number: | GVSUPS80K0B5GS |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | GVSUPS80K0B5GS |
| Active Output Power Rating Minimum Configuration (W): | 80000 |
| Apparent Output Power Rating Minimum Configuration (VA): | 80000 |
| Maximum Configuration Tested Model Number: | GVSUPS100K0B5GS |
| Active Output Power Rating Maximum Configuration (W): | 100000 |
| Topology (ac): | Multi-Mode Double Conversion |
| Topology and Product Type Combined: | ac - Other |
| Application: | Data Center |
| Rated Input Voltage (V rms): | 480-480 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 480-480 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | No |
| Height (mm): | 1970 |
| Width (mm): | 550 |
| Depth (mm): | 847 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Independent, Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Multiple-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Independent |
| Test Input Voltage (V rms): | 480 |
| | |

| Test Input Frequency (Hz): | 60 |
|--------------------------------------------------------------------------|--------|
| Test Output Voltage (V): | 480 |
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 478.12 |
| Total Input Power in W at 0% Load Min Config Highest Dependency (ac): | 283.71 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 95.3 |
| Efficiency at 25% Load Min Config Highest Dependency (ac): | 98.4 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 96.4 |
| Efficiency at 50% Load Min Config Highest Dependency (ac): | 99.0 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 96.7 |
| Efficiency at 75% Load Min Config Highest Dependency (ac): | 99.2 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 96.7 |
| Efficiency at 100% Load Min Config Highest Dependency (ac): | 99.3 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 96.2 |
| Weighted Efficiency Calc Min Config Highest Dependency: | 98.9 |
| Minimum Configuration Input Power Factor Highest-Input Dependency: | 0.98 |
| Total Input Power in W at 0% Load Max Config Lowest Dependency (ac): | 463.62 |
| Total Input Power in W at 0% Load Max Config Highest Dependency (ac): | 281.91 |
| Efficiency at 25% Load Max Config Lowest Dependency (ac): | 95.7 |
| Efficiency at 25% Load Max Config Highest Dependency (ac): | 98.6 |
| Efficiency at 50% Load Max Config Lowest Dependency (ac): | 96.6 |
| Efficiency at 50% Load Max Config Highest Dependency (ac): | 99.1 |
| Efficiency at 75% Load Max Config Lowest Dependency (ac): | 96.7 |
| Efficiency at 75% Load Max Config Highest Dependency (ac): | 99.3 |
| Efficiency at 100% Load Max Config Lowest Dependency (ac): | 96.6 |
| Efficiency at 100% Load Max Config Highest Dependency (ac): | 99.3 |
| | |

| Weighted Efficiency Calc Max Config Lowest Dependency: | 96.4 |
|-----------------------------------------------------------------------|-------------------------------------------------------------------------------|
| Weighted Efficiency Calc Max Config Highest Dependency: | 99.0 |
| Maximum Configuration Input Power Factor Lowest-Input Dependency: | 1.0 |
| Maximum Configuration Input Power Factor Highest-Input Dependency: | 1.0 |
| Efficiency (%): | 96.2 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | N/A |
| Energy Storage System Runtime at 50% Load (min.): | N/A |
| Energy Storage System Warranty (yrs): | N/A |
| Energy Storage System Information URL: | N/A |
| Battery Recycling URL: | https://www.apc.com/us/en/who-we-are/sustainability/recycling- options.jsp |
| Network Connections Available: | Serial Port,Ethernet |
| Communication Protocols: | HTTP,HTTPS,Modbus TCP,SNMP (v1, 2 or 3),Modbus RTU |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | https://www.apc.com/us/en/who-we-are/sustainability/recycling- options.jsp |
| Model Web Page URL: | https://www.apc.com/shop/us/en/products/P-GVSUPS80K0B5GS |
| Test Method Guidelines: | https://www.apc.com/us/en/who-we-are/sustainability/ |
| Date Available on Market: | 2020-02-28 |
| Date Certified: | 2020-03-12 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |
| | |

Captured On: 07/15/2025