



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

Tripp Lite - AG-030D : BC500

Specifications

| | |
|--|--|
| ENERGY STAR Unique ID: | 2384214 |
| Brand Name: | Tripp Lite |
| Model Name: | AG-030D |
| Model Number: | BC500 |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | AG-030D |
| Active Output Power Rating Minimum Configuration (W): | 260 |
| Apparent Output Power Rating Minimum Configuration (VA): | 500 |
| Topology (ac): | Passive Standby |
| Topology and Product Type Combined: | Alternating Current (ac) - Offline (VFD) |
| Application: | Consumer,Commercial |
| Rated Input Voltage (V rms): | 185-120 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | No |
| Height (mm): | 105 |
| Width (mm): | 110 |
| Depth (mm): | 185 |
| Total Number of Outlets: | 8 |
| Number of Battery Backup and Surge Protected Outlets: | 4 |
| Number of Surge Protected Only Outlets: | 4 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Dependent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |
| Test Output Frequency (Hz): | 60 |

| | |
|---|---|
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 2.15 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 97.1 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.6 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 99.0 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 99.2 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 97.6 |
| Efficiency (%): | 97.6 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 2 |
| Energy Storage System Runtime at 50% Load (min.): | 7 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | N/A |
| Battery Recycling URL: | http://www.tripplite.com/en/support/recycling-program.cfm |
| Network Connections Available: | None |
| Communication Protocols: | None |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | http://www.tripplite.com/en/support/recycling-program.cfm |
| Model Web Page URL: | https://www.tripplite.com/120v-500va-260w-standby-ups-8-outlets-nema-5-15r-5-15p-plug-5-ft-cord-desktop-wall-mount~bc500 |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2018-01-15 |
| Date Certified: | 2021-09-07 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Captured On:
05/01/2025