

Tripp Lite - AG-0685 : VS900T

Specifications ENERGY STAR Unique ID: 2392855 Brand Name: Tripp Lite Model Name: AG-0685 Model Number: VS900T Power Conversion Mechanism: Static Minimum Configuration Tested Model Number: AG-0685 Active Output Power Rating Minimum Configuration (W): 480	
Brand Name: Tripp Lite Model Name: AG-0685 Model Number: VS900T Power Conversion Mechanism: Static Minimum Configuration Tested Model Number: AG-0685 Active Output Power Rating Minimum Configuration (W): 480	
Model Name: Model Number: VS900T Power Conversion Mechanism: Static Minimum Configuration Tested Model Number: Active Output Power Rating Minimum Configuration (W): AG-0685	
Model Number: Power Conversion Mechanism: Static Minimum Configuration Tested Model Number: Active Output Power Rating Minimum Configuration (W): VS900T AG-0685 AG-0685	
Power Conversion Mechanism: Minimum Configuration Tested Model Number: Active Output Power Rating Minimum Configuration (W): Static AG-0685 480	
Minimum Configuration Tested Model Number: Active Output Power Rating Minimum Configuration (W): AG-0685 480	
Number: Active Output Power Rating Minimum Configuration (W): 480	
Configuration (W):	
Apparent Output Power Rating Minimum 900 Configuration (VA):	
Topology (ac): Line Interactive	
Topology and Product Type Combined: ac Line Interactive (VI)	
Application: Consumer,Commercial	
Rated Input Voltage (V rms): 300-120	
Rated Input Frequency (Hz): 50-60	
Rated Output Voltage (V): 120-120	
Rated Output Frequency (Hz): 50-60	
Rack Mountable: No	
Height (mm): 142	
Width (mm): 102	
Depth (mm): 300	
Total Number of Outlets: 6	
Number of Battery Backup and Surge 4 Protected Outlets:	
Number of Surge Protected Only Outlets: 2	
Normal Mode(s) Input Dependency Characteristic (ac): Voltage Independent	
Modular UPS: No	
Number of Normal Modes: Single-normal-mode	
Default Normal Mode (ac): Voltage Independent	
Test Input Voltage (V rms): 120	
Test Input Frequency (Hz): 60	
Test Output Voltage (V): 120	
Test Output Frequency (Hz): 60	

	0.04
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	2.24
Efficiency at 25% Load Min Config Lowest Dependency (ac):	98.4
Efficiency at 50% Load Min Config Lowest Dependency (ac):	99.1
Efficiency at 75% Load Min Config Lowest Dependency (ac):	99.3
Efficiency at 100% Load Min Config Lowest Dependency (ac):	99.3
Weighted Efficiency Calc Min Config Lowest Dependency:	99.2
Efficiency (%):	99.2
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	No
Energy Storage System Runtime at 100% Load (min.):	1
Energy Storage System Runtime at 50% Load (min.):	4
Energy Storage System Warranty (yrs):	3
Energy Storage System Information URL:	N/A
Battery Recycling URL:	http://www.tripplite.com/en/support/recycling-program.cfm
Network Connections Available:	None
Communication Protocols:	None
Manufacturer Take Back Program:	Yes
Manufacturer Take Back Program URL:	http://www.tripplite.com/en/support/recycling-program.cfm
Model Web Page URL:	https://www.tripplite.com/120v-ups-line-interactive-900va-480w-tower-6-outlets-avr~vs900t
Test Method Guidelines:	N/A
Date Available on Market:	2019-09-03
Date Certified:	2022-02-08
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

Captured On: 06/17/2025