



ENERGY STAR CERTIFIED

# Uninterruptible Power Supplies

## Liebert - GXT5LI-10KMVRT4UXLN : GXT5LI-10KMVRT4UXLN

### Specifications

|  |   |
|--|---|
| ENERGY STAR Unique ID:   | 2401107   |
| Brand Name:  | Liebert   |
| Model Name:  | GXT5LI-10KMVRT4UXLN   |
| Model Number:  | GXT5LI-10KMVRT4UXLN   |
| Power Conversion Mechanism:  | Static  |
| Minimum Configuration Tested Model Number:                           | GXT5LI-10KMVRT4UXLN   |
| Active Output Power Rating Minimum Configuration (W):                | 10000   |
| Apparent Output Power Rating Minimum Configuration (VA):             | 10000   |
| Topology (ac):   | Multi-Mode Double Conversion                                      |
| Topology and Product Type Combined:                                  | ac - Other  |
| Application:   | Data Center,Consumer,Commercial                                   |
| Rated Input Voltage (V rms):   | 173-217   |
| Rated Input Frequency (Hz):  | 50-60   |
| Rated Output Voltage (V):  | 200-217   |
| Rated Output Frequency (Hz):   | 50-60   |
| Rack Mountable:  | Yes   |
| Height (mm):   | 85  |
| Width (mm):  | 430   |
| Depth (mm):  | 930   |
| Normal Mode(s) Input Dependency Characteristic (ac):                 | Voltage and Frequency Independent,Voltage and Frequency Dependent |
| Modular UPS:   | No  |
| Number of Normal Modes:  | Multiple-normal-mode  |
| Default Normal Mode (ac):  | Voltage and Frequency Independent                                 |
| Test Input Voltage (V rms):  | 208   |
| Test Input Frequency (Hz):   | 60  |
| Test Output Voltage (V):   | 208   |
| Test Output Frequency (Hz):  | 60  |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 53.04   |

|  |   |
|--|---|
| <b>Total Input Power in W at 0% Load Min Config Highest Dependency (ac):</b> | 31.35   |
| <b>Efficiency at 25% Load Min Config Lowest Dependency (ac):</b>             | 94.4  |
| <b>Efficiency at 25% Load Min Config Highest Dependency (ac):</b>            | 98.9  |
| <b>Efficiency at 50% Load Min Config Lowest Dependency (ac):</b>             | 94.1  |
| <b>Efficiency at 50% Load Min Config Highest Dependency (ac):</b>            | 99.3  |
| <b>Efficiency at 75% Load Min Config Lowest Dependency (ac):</b>             | 93.5  |
| <b>Efficiency at 75% Load Min Config Highest Dependency (ac):</b>            | 99.1  |
| <b>Efficiency at 100% Load Min Config Lowest Dependency (ac):</b>            | 92.5  |
| <b>Efficiency at 100% Load Min Config Highest Dependency (ac):</b>           | 98.4  |
| <b>Weighted Efficiency Calc Min Config Lowest Dependency:</b>                | 93.4  |
| <b>Minimum Configuration Input Power Factor Highest-Input Dependency:</b>    | 0.99  |
| <b>Efficiency (%):</b>   | 93.4  |
| <b>Modular UPS Module Tested Model Number:</b>                               | N/A   |
| <b>Energy Storage Mechanism:</b>   | Battery   |
| <b>Energy Storage System Technology:</b>                                     | Lithium-ion Battery   |
| <b>Energy Storage System Configuration:</b>                                  | Separate Enclosure  |
| <b>Energy Storage System Removable to Another Room:</b>                      | No  |
| <b>Energy Storage System Runtime at 100% Load (min.):</b>                    | 10  |
| <b>Energy Storage System Runtime at 50% Load (min.):</b>                     | 20  |
| <b>Energy Storage System Warranty (yrs):</b>                                 | 1   |
| <b>Energy Storage System Information URL:</b>                                | <a href="http://www.enersys.com/">http://www.enersys.com/</a> <a href="http://www.eastpennunigy.com/">http://www.eastpennunigy.com/</a>   |
| <b>Network Connections Available:</b>  | USB Port  |
| <b>Communication Protocols:</b>  | Other   |
| <b>Manufacturer Take Back Program:</b>                                       | No  |
| <b>Model Web Page URL:</b>   | <a href="https://www.vertivco.com/en-us/products-catalog/critical-power/uninterruptible-power-supplies-ups/">https://www.vertivco.com/en-us/products-catalog/critical-power/uninterruptible-power-supplies-ups/</a> |
| <b>Test Method Guidelines:</b>   | N/A   |
| <b>Date Available on Market:</b>   | 2022-09-05  |
| <b>Date Certified:</b>   | 2022-08-29  |
| <b>Markets:</b>  | United States, Taiwan, Japan, Canada  |
| <b>ENERGY STAR Certified:</b>  | Yes   |

**Captured On:**  
06/19/2025