

## Minuteman - ETR850LG : ETR850LG

Specifications	
ENERGY STAR Unique ID:	2405485
Brand Name:	Minuteman
Model Name:	ETR850LG
Model Number:	ETR850LG
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	ETR850LG
Active Output Power Rating Minimum Configuration (W):	510
Apparent Output Power Rating Minimum Configuration (VA):	850
Topology (ac):	Line Interactive
Topology and Product Type Combined:	ac Line Interactive (VI)
Application:	Data Center,Consumer,Commercial
Rated Input Voltage (V rms):	120-120
Rated Input Frequency (Hz):	60-60
Rated Output Voltage (V):	120-120
Rated Output Frequency (Hz):	60-60
Rack Mountable:	No
Height (mm):	280
Width (mm):	99
Depth (mm):	288
Total Number of Outlets:	8
Number of Battery Backup and Surge Protected Outlets:	4
Number of Surge Protected Only Outlets:	4
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage Independent
Test Input Voltage (V rms):	120
Test Input Frequency (Hz):	60
Test Output Voltage (V):	120
Test Output Frequency (Hz):	60

Efficiency at 25% Load Min Config Lowest Dependency (ac):	97.4
Efficiency at 50% Load Min Config Lowest Dependency (ac):	98.4
Efficiency at 75% Load Min Config Lowest Dependency (ac):	98.6
Efficiency at 100% Load Min Config Lowest Dependency (ac):	98.5
Weighted Efficiency Calc Min Config Lowest Dependency:	98.5
Efficiency (%):	98.5
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	N/A
Energy Storage System Runtime at 100% Load (min.):	2
Energy Storage System Runtime at 50% Load (min.):	10
Energy Storage System Warranty (yrs):	2
Energy Storage System Information URL:	https://minutemanups.com/uninterruptible-power-supply/
Battery Recycling URL:	https://minutemanups.com/contact/
Network Connections Available:	USB Port
Communication Protocols:	Other
Communication Protocol Other:	HID
Manufacturer Take Back Program:	Yes
Manufacturer Take Back Program URL:	https://minutemanups.com/contact/
Model Web Page URL:	https://minutemanups.com/uninterruptible-power-supply/entrust-lg- uninterruptible-power-supply
Test Method Guidelines:	N/A
Date Available on Market:	2023-04-01
Date Certified:	2022-12-12
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

Captured On: 06/12/2025