

Liebert - EXL 0825kTK56FN01000 : EXL 0825kTK56FN01000

| Specifications | |
|--|--|
| ENERGY STAR Unique ID: | 2421040 |
| Brand Name: | Liebert |
| Model Name: | EXL 0825kTK56FN01000 |
| Model Number: | EXL 0825kTK56FN01000 |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | EXL 0825kTK56FN01000 |
| Active Output Power Rating Minimum Configuration (W): | 743000 |
| Apparent Output Power Rating Minimum Configuration (VA): | 825000 |
| Topology (ac): | Multi-Mode Double Conversion |
| Topology and Product Type Combined: | ac - Other |
| Application: | Data Center,Consumer,Commercial |
| Rated Input Voltage (V rms): | 430-528 |
| Rated Input Frequency (Hz): | 45-66 |
| Rated Output Voltage (V): | 480-480 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | No |
| Height (mm): | 2150 |
| Width (mm): | 2003 |
| Depth (mm): | 975 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Independent, Voltage and Frequency Dependent |
| Modular UPS: | No |
| Number of Normal Modes: | Multiple-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Dependent |
| Test Input Voltage (V rms): | 480 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 480 |
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 4812.32 |

| Total Input Power in W at 0% Load Min Config Highest Dependency (ac): | 2528.85 |
|---|---|
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 97.0 |
| Efficiency at 25% Load Min Config Highest Dependency (ac): | 99.5 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 97.0 |
| Efficiency at 50% Load Min Config Highest Dependency (ac): | 99.8 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 97.1 |
| Efficiency at 75% Load Min Config Highest Dependency (ac): | 99.9 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 97.0 |
| Efficiency at 100% Load Min Config Highest Dependency (ac): | 99.9 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 97.0 |
| Weighted Efficiency Calc Min Config Highest Dependency: | 99.8 |
| Minimum Configuration Input Power Factor Highest-Input Dependency: | 0.99 |
| Efficiency (%): | 97.7 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Separate Enclosure |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 15 |
| Energy Storage System Runtime at 50% Load (min.): | 30 |
| Energy Storage System Warranty (yrs): | 5 |
| Energy Storage System Information URL: | http://www.enersys.com/ http://www.eastpennunigy.com/ |
| Network Connections Available: | Serial Port |
| Communication Protocols: | Modbus TCP,SNMP (v1, 2 or 3),Modbus RTU |
| Manufacturer Take Back Program: | No |
| Model Web Page URL: | https://www.vertiv.com/en-us/products-catalog/critical-power/uninterruptible-power-supplies-ups/liebert-exl-s1/ |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2023-07-01 |
| Date Certified: | 2023-03-14 |
| Markets: | United States, Taiwan, Japan, Canada |
| ENERGY STAR Certified: | Yes |
| | |

Captured On: 05/01/2025