

## Minuteman - ED10KRT : ED10KRT

Specifications	
ENERGY STAR Unique ID:	3417795
Brand Name:	Minuteman
Model Name:	ED10KRT
Model Number:	ED10KRT
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	ED10KRT
Active Output Power Rating Minimum Configuration (W):	9000
Apparent Output Power Rating Minimum Configuration (VA):	10000
Topology (ac):	Double Conversion
Topology and Product Type Combined:	ac - Double Conversion (VFI)
Application:	Data Center,Consumer,Commercial
Rated Input Voltage (V rms):	208-240
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	208-240
Rated Output Frequency (Hz):	50-60
Rack Mountable:	Yes
Rack Mount Height (U):	5
Height (mm):	217
Width (mm):	438
Depth (mm):	730
Total Number of Outlets:	6
Number of Battery Backup and Surge Protected Outlets:	6
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	230
Test Input Frequency (Hz):	60
Test Output Voltage (V):	240

Test Output Frequency (Hz):60	
<b>Efficiency at 25% Load Min Config Lowest</b> 93. <b>Dependency (ac):</b>	3.1
Efficiency at 50% Load Min Config Lowest 94. Dependency (ac):	l.0
Efficiency at 75% Load Min Config Lowest 94. Dependency (ac):	l.0
Efficiency at 100% Load Min Config Lowest 93. Dependency (ac):	3.7
Weighted Efficiency Calc Min Config Lowest 93. Dependency:	3.9
Efficiency (%): 93.	3.9
Modular UPS Module Tested Model Number: N/A	Ά
Energy Storage Mechanism: Ba	attery
Energy Storage System Technology: Val	alve Regulated Lead-acid Battery
Energy Storage System Configuration:	tegral
Energy Storage System Removable to Another N/A Room:	Ά
Energy Storage System Runtime at 100% Load 2 (min.):	
Energy Storage System Runtime at 50% Load 7 (min.):	
Energy Storage System Warranty (yrs): 3	
Energy Storage System Information URL: N/A	Ά
Network Connections Available: Set	erial Port,USB Port
Communication Protocols: SN	MP (v1, 2 or 3)
Manufacturer Take Back Program: No	0
	tps://minutemanups.com/uninterruptible-power-supply/ ideavor-5-10kva-online-uninterruptible-power-supply-2/
Test Method Guidelines: N/A	Ά
Date Available on Market: 202	024-03-18
Date Certified: 202	024-02-29
Markets: Un	nited States, Canada
ENERGY STAR Certified: Yes	25

**Captured On:** 05/01/2025