

Minuteman - ED8KRT : ED8KRT

| Specifications | |
|---|-----------------------------------|
| ENERGY STAR Unique ID: | 3417796 |
| Brand Name: | Minuteman |
| Model Name: | ED8KRT |
| Model Number: | ED8KRT |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | ED8KRT |
| Active Output Power Rating Minimum Configuration (W): | 7200 |
| Apparent Output Power Rating Minimum Configuration (VA): | 8000 |
| Topology (ac): | Double Conversion |
| Topology and Product Type Combined: | ac - Double Conversion (VFI) |
| Application: | Data Center,Consumer,Commercial |
| Rated Input Voltage (V rms): | 208-240 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 208-240 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | Yes |
| Rack Mount Height (U): | 5 |
| Height (mm): | 217 |
| Width (mm): | 438 |
| Depth (mm): | 730 |
| Total Number of Outlets: | 6 |
| Number of Battery Backup and Surge Protected Outlets: | 6 |
| Number of Surge Protected Only Outlets: | 0 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Independent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Independent |
| Test Input Voltage (V rms): | 230 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 240 |
| | |

| | (0 |
|---|---|
| Test Output Frequency (Hz): | 60 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 92.3 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 94.0 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 94.2 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 93.9 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 94.1 |
| Efficiency (%): | 94.1 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | N/A |
| Energy Storage System Runtime at 100% Load (min.): | 3 |
| Energy Storage System Runtime at 50% Load (min.): | 11 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | N/A |
| Network Connections Available: | Serial Port,USB Port |
| Communication Protocols: | SNMP (v1, 2 or 3) |
| Manufacturer Take Back Program: | No |
| Model Web Page URL: | https://minutemanups.com/uninterruptible-power-supply/ endeavor-5-10kva-online-uninterruptible-power-supply-2/ |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2024-03-18 |
| Date Certified: | 2024-02-29 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Captured On: 06/18/2025