

Vertiv - Liebert APM2 FR1 c3 Series : 56S(c3)(d2)P(f)(g)(h) (i)(j)

Specifications	
ENERGY STAR Unique ID:	3815211
Brand Name:	Vertiv
Model Name:	Liebert APM2 FR1 c3 Series
Model Number:	56S(c3)(d2)P(f)(g)(h)(i)(j)
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	56S(c3)(d2)C(f)(g)(h)(i)(j)
Active Output Power Rating Minimum Configuration (W):	20000
Apparent Output Power Rating Minimum Configuration (VA):	20000
Maximum Configuration Tested Model Number:	56S(c3)(d2)P(f)(g)(h)(i)(j)
Active Output Power Rating Maximum Configuration (W):	120000
Topology (ac):	Multi-Mode Double Conversion
Topology and Product Type Combined:	ac - Other
Application:	Data Center,Consumer,Commercial
Rated Input Voltage (V rms):	480-480
Rated Input Frequency (Hz):	60-60
Rated Output Voltage (V):	480-480
Rated Output Frequency (Hz):	60-60
Rack Mountable:	No
Height (mm):	2000
Width (mm):	600
Depth (mm):	1029
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Independent, Voltage and Frequency Dependent
Modular UPS:	Yes
Number of Normal Modes:	Multiple-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Independent
Test Input Voltage (V rms):	480
Test Input Frequency (Hz):	60
Test Output Voltage (V):	480

T - 1 O - 1 - 1 F (11-)	60
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	183.68
Total Input Power in W at 0% Load Min Config Highest Dependency (ac):	70.19
Efficiency at 25% Load Min Config Lowest Dependency (ac):	94.3
Efficiency at 25% Load Min Config Highest Dependency (ac):	98.0
Efficiency at 50% Load Min Config Lowest Dependency (ac):	96.1
Efficiency at 50% Load Min Config Highest Dependency (ac):	99.1
Efficiency at 75% Load Min Config Lowest Dependency (ac):	96.6
Efficiency at 75% Load Min Config Highest Dependency (ac):	99.4
Efficiency at 100% Load Min Config Lowest Dependency (ac):	96.9
Efficiency at 100% Load Min Config Highest Dependency (ac):	99.0
Weighted Efficiency Calc Min Config Lowest Dependency:	95.8
Weighted Efficiency Calc Min Config Highest Dependency:	98.9
Minimum Configuration Input Power Factor Highest-Input Dependency:	0.99
Total Input Power in W at 0% Load Max Config Lowest Dependency (ac):	1259.52
Total Input Power in W at 0% Load Max Config Highest Dependency (ac):	683.28
Efficiency at 25% Load Max Config Lowest Dependency (ac):	95.6
Efficiency at 25% Load Max Config Highest Dependency (ac):	98.8
Efficiency at 50% Load Max Config Lowest Dependency (ac):	96.5
Efficiency at 50% Load Max Config Highest Dependency (ac):	99.0
Efficiency at 75% Load Max Config Lowest Dependency (ac):	96.9
Efficiency at 75% Load Max Config Highest Dependency (ac):	99.3
Efficiency at 100% Load Max Config Lowest Dependency (ac):	97.0
Efficiency at 100% Load Max Config Highest Dependency (ac):	99.3
Weighted Efficiency Calc Max Config Lowest Dependency:	96.4
Weighted Efficiency Calc Max Config Highest Dependency:	99.0

Maximum Configuration Input Power Factor Lowest-Input Dependency: Maximum Configuration Input Power Factor Highest-Input Dependency: Efficiency (%): 95.8 Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Energy Storage System Warranty (yrs): 1 0.99 0.90 0
Highest-Input Dependency: Efficiency (%): Modular UPS Module Tested Model Number: 56S(c3)(d2)C(f)(g)(h)(i)(j), 56S(c3)(d2)P(f)(g)(h)(i)(j) Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.):
Modular UPS Module Tested Model Number: 56S(c3)(d2)C(f)(g)(h)(i)(j), 56S(c3)(d2)P(f)(g)(h)(i)(j) Energy Storage Mechanism: Battery Energy Storage System Technology: Valve Regulated Lead-acid Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.):
Energy Storage Mechanism: Energy Storage System Technology: Valve Regulated Lead-acid Battery Integral Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): 40
Energy Storage System Technology: Energy Storage System Configuration: Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): 40
Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): Additional Integral No 20 40
Energy Storage System Removable to Another Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): 40
Room: Energy Storage System Runtime at 100% Load (min.): Energy Storage System Runtime at 50% Load (min.): 40
(min.): Energy Storage System Runtime at 50% Load (min.): 40
(min.):
Energy Storage System Warranty (yrs): 1
Energy Storage System Information URL: http://www.enersys.com, http://www.eastpennunigy.com/
Network Connections Available: USB Port
Communication Protocols: Other
Manufacturer Take Back Program: No
Model Web Page URL: https://www.vertivco.com/en-us/products-catalog/critical-power/uninterruptible-power-supplies-ups/
Test Method Guidelines: N/A
Date Available on Market: 2024-10-30
Date Certified: 2024-11-28
Markets: United States, Canada
ENERGY STAR Certified: Yes

Additional Model Information

Liebert APM2 FR1 c3 Series,56S(c3)(d2)E(f)(g)(h)(i)(j),; Liebert APM2 FR1 c3 Series,56S(c3)(d2)F(f)(g)(h)(i)(j),; Liebert APM2 FR1 c3 Series,56S(c3)(d2)J(f)(g)(h)(i)(j),; Liebert APM2 FR1 c3 Series,56S(c3)(d2)J(f)(g)(h)(i)(j),

Captured On: 05/01/2025